

PHOENIX MEDICAL SYSTEMS (P) LTD TEST REPORT

SCOPE OF WORKS

Testing and Issue of test report for ventilation system as per client requirements [NUMO]

REPORT NUMBER

CE-JOB-BAN-20-000740-001

ISSUE DATE

24-July-2020

[REVISED DATE]

[None]


PAGES

7

DOCUMENT CONTROL NUMBER

GFT-OP-10b (18 April-2017)

© 2017 INTERTEK



TEST REPORT FOR PHOENIX MEDICAL SYSTEMS (P) LTD

Report No.: CE-JOB-BAN-20-000740-001

Date: July, 24, 2020

OBJECTIVE

To verify the functionality of the ventilator system on accuracy of controls and instruments.

HYPOTHESIS

To verify the functionality of the ventilator system for various inflation types.

CONCLUSION

Based on the data collected the Hypothesis is accepted: Yes

Based on the data collected the Hypothesis is rejected: No

The test is for information only, the data is supplied to the client without conclusion. Final evaluation to be conducted by the client



Uday Kumar H
ENGINEER



Gnanaprakasam. C
REVIEWER

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to copy or distribute Intertek's Reports and then only in their entirety, and the Client shall not use the Reports in a misleading manner. Client further agrees and understands that reliance upon the Reports is limited to the representations made therein. In the event any portion of this report becomes public, including but not limited to press releases, articles, and marketing material, without prior written consent from Intertek, Intertek will enforce the reproduction of the report in its entirety by making the full report public. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. Should Customer use an Intertek Report, in whole or in part, in such a manner as to involve Intertek in legal controversy or to adversely affect Intertek's reputation, it shall be Intertek's right to utilize any and all Customer information, including, but not limited to, data, records, instructions, notations, samples or documents within Intertek's custody and control which relate to the customer for the purpose of offering any necessary defense or rebuttal to such circumstances. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.